

# VOC Content Test Certificate

Tuesday 21<sup>st</sup> September 2021

Supplier: Parchem Construction Supplies Pty Ltd (1956 Dandenong Rd, Clayton, VIC, 3168, Australia)

Product Description: Emer-Seal® Paintable FC

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

**Test Data:**


<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Emer-Seal® Paintable FC</b>
<b>General Purpose Adhesives and Sealants: 50 grams per Liter</b>	<b>12 grams per Liter as VOC content per material</b>
<p><i>We hereby certify that Emer-Seal® Paintable FC is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BEng (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

**V2109022**